

.

From: Nassif, Julianne (DPH)
Sent: Wednesday, March 16, 2011 8:11 AM
To: 'Jill.Clemmer@state.ma.us'; 'Peter.Kane01@state.ma.us'; Servizio, Paul (DPH); Piro, Peter (DPH); Salemi, Charles (DPH); Rubin, Alan (DPH)
Subject: Fw:

See note below

----- Original Message -----

From: Connolly, Grace (DPH)
Sent: Wednesday, March 16, 2011 06:47 AM
To: Caloggero, Dina (DPH); Smole, Sandra (DPH)
Cc: Nassif, Julianne (DPH)
Subject: Fw:

----- Original Message -----

From: Mitchell, Jay [<mailto:Jay.Mitchell@umassmed.edu>]
Sent: Tuesday, March 15, 2011 07:48 PM
To: Grace Connolly <Grace.Connolly@state.ma.us>; Linda Han <Linda.Han@state.ma.us>
Subject:

There was manhole fire on Washington st. It has knocked out power to Stable and bio blds. Those buildings are on generator. SLI is fine.

There was some flickering in the SLI but power is working fine.

However there was flickering on the 6 th floor and a couple computers needed to be rebooted. This fire happened 45 minutes ago.

May need to check equipment if necessary if it can't wait til AM. If there is any change I will let you know. Please let me know you got this. Thanks

Sent from my iPhone